



E/F نتایج مشروح محاسبات رله های

Company or Region Name = ZREC

Group or Checker Name = Group\_1

Substation Name = Test\_230kV\_OK

Voltage = 230 / 63 kV

Calculation date & time = 2016 / 2 / 8 on Monday at 16:34:4

Transformer(s) Type = Autotransformer

S [Power Transformer(s) apparent power] = 160 MVA

Sbase = 100 MVA

محاسبات آزمایشی Comment for this Calculation:

Short circuit results :

Earth Fault Currents:

جريان خطای تکفارز دیده شده توسط رله فیدر های خروجی در حالت ماکزیمم سطح اتصال کوتاه شبکه و حضور ترانس های موازی

IE1(Substation) = 2.54 pu ==> 2327.73 A

جريان خطای تکفارز فیدرکوپلاژ در حالت ماکزیمم سطح اتصال کوتاه شبکه و حالت تک ترانسی بدون در نظر گرفتن ترانس های تزریقی پست های مجاور متصل به فیدر های خروجی

IE2(Substation) = 1.296 pu ==> 1187.69 A

جريان خطای تکفارز فیدر سمت اولیه در حالت ماکزیمم سطح اتصال کوتاه شبکه بدون در نظر گرفتن اثر جريان تزریقی پست های مجاور متصل به فیدر های خروجی

IE3(Substation) = 32.42 pu ==> 8138.13 A

جريان خطای تکفارز فیدر های خروجی در حالت مینیمم سطح اتصال کوتاه شبکه و حالت تک ترانسی

IE4(Substation) = 1.228 pu ==> 1125.37 A

حاصل تقسیم جريان خطای تکفارز فیدرکوپلاژ بر تعداد ترانس ها در حالت مینیمم سطح اتصال کوتاه شبکه و حضور ترانس های موازی

IE5(Substation) = 1.14 pu ==> 1044.73 A

جريان خطای تکفارز فیدر سمت اولیه در حالت مینیمم سطح اتصال کوتاه شبکه

IE6(Substation) = 10.899 pu ==> 2735.89 A

جريان های اتصال کوتاه زمین مورد استفاده در محاسبات

IeMax(1) = 2327.73 A

IeMax(2) = 1187.69 A

IeMax(3) = 1187.69 A

IeMax(4) = 1187.69 A

IeMax(5) = 8138.13 A

IeMax(6) = 1187.69 A



$I_{eMin}(1) = 1125.37 \text{ A}$   
 $I_{eMin}(2) = 1044.73 \text{ A}$   
 $I_{eMin}(3) = 1044.73 \text{ A}$   
 $I_{eMin}(4) = 1044.73 \text{ A}$   
 $I_{eMin}(5) = 2735.89 \text{ A}$   
 $I_{eMin}(6) = 1044.73 \text{ A}$

-----<< E/F Protection >>-----  
 Earth Fault Protective Relay R1(1) for 63 kV Outgoing Feeder 'A1'

Relay Type: MCGG82

Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} Gama + Beta\} = (TMS/1) \times$

$\{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02 ; Beta = 0 ; Gama = 1 ; K = 0.14 ; M = 1$

$I_n = 1 \text{ A}$  ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 800 / 1$

Feeder type: Line

Connected to Section Nr. 1

Direction: Line side

$I_{base} = 916.43 \text{ A}$  ; Base Current

$I_{e1}(A1) = 2.541 \text{ pu} = 2328.65 \text{ A}$  ; Maximum 1-ph short circuit at forward Line beginning, seen by this Relay

$I_{e2}(A1) = 2.147 \text{ pu} = 1967.57 \text{ A}$  ; Maximum 1-ph short circuit at forward Line end, seen by this Relay

$I_{e5}(A1) = 0.92 \text{ pu} = 843.11 \text{ A}$  ; Minimum 1-ph short circuit, seen by this Relay

$ISR(A1) = 0.1 \times \min[I_{1CT}, I(LTR)] = 0.1 \times \min[800, 549] = 54.9 \text{ A}$

$I_s = [ISR(A1) / 800] \times I_n = 0.069 \times I_n$  ; Best Norm ==>  $0.1 \times I_n$

$ISR(A1) = 0.1 \times 800 = 80 \text{ A}$

Checking:  $I_{e5}(A1) / ISR(A1) = 10.54$

$TMS(\text{Final}) = \max [\text{User defined TMS or Calculated TMS}] = 1$  ; Best Norm ==> 1

$I_{inst} = 1 \times [I_{e1} / ISR(A1)] \times I_s = 29.11 \times I_s$  ; Best Norm ==>  $29 \times I_s$

$T_{inst} = 0 \text{ sec}$ ; Norm ==> 0 sec

Checking:  $[(I_{e1} - I_{e2}) / I_{e1}] \times 100 = 15.5 \%$  ; !!!!!!! It is < 20 %

-----<< E/F Protection >>-----  
 Earth Fault Protective Relay R1(2) for 63 kV Outgoing Feeder 'A2'

Relay Type: MCGG82

Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} Gama + Beta\} = (TMS/1) \times$

$\{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$



alfa = 0.02 ; Beta = 0 ; Gama = 1 ; K = 0.14 ; M = 1

In = 1 A ; Relay Nominal Current

C.T Ratio = I1CT / I2CT = 800 / 1

Feeder type: Line

Connected to Section Nr. 1

Direction: Line side

Ibase = 916.43 A ; Base Current

le1(A2) = 2.541 pu = 2328.65 A ; Maximum 1-ph short circuit at forward Line beginning, seen by this Relay

le2(A2) = 0.735 pu = 673.58 A ; Maximum 1-ph short circuit at forward Line end, seen by this Relay

le5(A2) = 0.5 pu = 458.21 A ; Minimum 1-ph short circuit, seen by this Relay

ISR(A2) =  $0.1 \times \text{Min}[I1CT, I(LTR)] = 0.1 \times \text{Min}[800, 489] = 48.9 \text{ A}$

Is = [ISR(A2) / 800] × In = 0.061 × In ; Best Norm ==> 0.1 × In

ISR(A2) =  $0.1 \times 800 = 80 \text{ A}$

Checking: le5(A2) / ISR(A2) = 5.73

TMS according to required Relay Operating time for Faults in the Forward Line Beginning (Zone 1):

TMS1 =  $0.4 \times 1 / \{0.14 / [(le1(A2) / ISR(A2)) ^ 0.02 - 1] + 0\} = 0.199$

TMS according to required Relay Operating time for Faults in the Forward Line End (Zone 2):

TMS2 =  $0.8 \times 1 / \{0.14 / [(le2(A2) / ISR(A2)) ^ 0.02 - 1] + 0\} = 0.249$

TMS(Final) = Max [User defined TMS or Calculated TMS] = 0.249 ; Best Norm ==> 0.25

Iinst =  $1 \times [le1 / ISR(A2)] \times Is = 29.11 \times Is$  ; Best Norm ==>  $29 \times Is$

Tinst = 0 sec; Norm ==> 0 sec

Checking:  $[(le1 - le2) / le1] \times 100 = 71.1 \%$

-----<< E/F Protection >>-----

Earth Fault Protective Relay R1(3) for 63 kV Outgoing Feeder 'A3'

Relay Type: MCGG82

Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/Is)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/Is)^{0.02 - 1}]^1 + 0\}$

alfa = 0.02 ; Beta = 0 ; Gama = 1 ; K = 0.14 ; M = 1

In = 1 A ; Relay Nominal Current

C.T Ratio = I1CT / I2CT = 800 / 1

Feeder type: Reactor



Connected to Section Nr. 1

Direction: Busbar side

$I_{base} = 916.43 \text{ A}$  ; Base Current

$I_{e3(A3)} = 1 \text{ pu} = 916.43 \text{ A}$  ; Maximum 1-ph short circuit at reverse Line beginning  
(if any)

$I_{e4(A3)} = 1 \text{ pu} = 916.43 \text{ A}$  ; Maximum 1-ph short circuit at reverse Line end (if any)

$I_{e5(A3)} = 0.83 \text{ pu} = 760.64 \text{ A}$  ; Minimum 1-ph short circuit, seen by this Relay

$$ISR(A3) = 0.1 \times \min[I1CT, I(LTR)] = 0.1 \times \min[800, 549] = 54.9 \text{ A}$$

$$I_s = [ISR(A3) / 800] \times I_n = 0.069 \times I_n ; \text{Best Norm} \implies 0.1 \times I_n$$

$$ISR(A3) = 0.1 \times 800 = 80 \text{ A}$$

$$\text{Checking: } I_{e5(A2)} / ISR(A3) = 5.73$$

Coordination with Line E/F Relays:

$$T(A1) = 1 / 1 \times \{0.14 / [(I_{e3(A3)} / ISR(A1))^{0.02 - 1}] + 0\} = 2.007 \text{ sec}$$

$$T(A3) = T(A1) + 0.4 = 2.407 \text{ sec}$$

$$TMS(A3) = 2.407 \times 1 / \{0.14 / [(I_{e3(A3)} / ISR(A3))^{0.02 - 1}] + 0\} = 1.199$$

Coordination with Line E/F Relays:

$$T(A2) = 0.25 / 1 \times \{0.14 / [(I_{e3(A3)} / ISR(A2))^{0.02 - 1}] + 0\} = 0.502 \text{ sec}$$

$$T(A3) = T(A2) + 0.4 = 0.902 \text{ sec}$$

$$TMS(A3) = 0.902 \times 1 / \{0.14 / [(I_{e3(A3)} / ISR(A3))^{0.02 - 1}] + 0\} = 0.449$$

$$TMS(\text{Final}) = \max[\text{User defined TMS or Calculated TMS}] = 1.199 ; \text{Best Norm} \implies 1$$

$$I_{inst} = 1 \times [I_{e3} / ISR(A3)] \times I_s = 11.46 \times I_s ; \text{Best Norm} \implies 11 \times I_s$$

$$T_{inst} = 0 \text{ sec} ; \text{Norm} \implies 0 \text{ sec}$$

-----<< E/F Protection >>-----  
Earth Fault Protective Relay R1(4) for 63 kV Outgoing Feeder 'A4'

Relay Type: MCGG62

Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} Gama + Beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$

$$\alpha = 0.02 ; \Beta = 0 ; \Gamma = 1 ; K = 0.14 ; M = 1$$

$I_n = 1 \text{ A}$  ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 800 / 1$

Feeder type: Cap-Bank

Connected to Section Nr. 2

Direction: Non Directional

$I_{base} = 916.43 \text{ A}$  ; Base Current



$I_{e1}(A4) = 2.5 \text{ pu} = 2291.07 \text{ A}$  ; Maximum 1-ph short circuit at forward Line beginning, seen by this Relay  
 $I_{e2}(A4) = 1.7 \text{ pu} = 1557.93 \text{ A}$  ; Maximum 1-ph short circuit at forward Line end, seen by this Relay  
 $I_{e3}(A4) = 1 \text{ pu} = 916.43 \text{ A}$  ; Maximum 1-ph short circuit at reverse Line beginning (if any), seen by this Relay  
 $I_{e4}(A4) = 1 \text{ pu} = 916.43 \text{ A}$  ; Maximum 1-ph short circuit at reverse Line end (if any), seen by this Relay  
 $I_{e5}(A4) = 0.9 \text{ pu} = 824.79 \text{ A}$  ; Minimum 1-ph short circuit, seen by this Relay

$$ISR(A4) = 0.1 \times \min[I_{1CT}, I(LTR)] = 0.1 \times \min[800, 549] = 54.9 \text{ A}$$

$$I_s = [ISR(A4) / 800] \times I_n = 0.069 \times I_n ; \text{Best Norm} ==> 0.05 \times I_n$$

$$ISR(A4) = 0.05 \times 800 = 40 \text{ A}$$

Checking:  $I_{e5}(A2) / ISR(A4) = 11.46$

Coordination with Line E/F Relays:

$$T(A1) = 1 / 1 \times \{0.14 / [(I_{e3}(A4) / ISR(A1))^{0.02 - 1}] + 0\} = 2.801 \text{ sec}$$

$$T(A4) = T(A1) + 0.4 = 3.201 \text{ sec}$$

$$TMS(A4) = 3.201 \times 1 / \{0.14 / [(I_{e3}(A4) / ISR(A4))^{0.02 - 1}] + 0\} = 1.478$$

Coordination with Line E/F Relays:

$$T(A2) = 0.25 / 1 \times \{0.14 / [(I_{e3}(A4) / ISR(A2))^{0.02 - 1}] + 0\} = 0.7 \text{ sec}$$

$$T(A4) = T(A2) + 0.4 = 1.1 \text{ sec}$$

$$TMS(A4) = 1.1 \times 1 / \{0.14 / [(I_{e3}(A4) / ISR(A4))^{0.02 - 1}] + 0\} = 0.508$$

$TMS(\text{Final}) = \max[\text{User defined TMS or Calculated TMS}] = 1.478$  ; Best Norm ==> 1

$I_{inst} = \text{Infinity}$

$T_{inst} = 0 \text{ sec}$ ; Norm ==> 0 sec

-----<< E/F Protection >>-----  
 Earth Fault Protective Relay R2(1) for 63 KV at Buscoupler feeder 'Bus\_LV\_1'

Relay Type: MCGG82

Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\Gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$

$\alpha = 0.02$  ;  $\beta = 0$  ;  $\Gamma = 1$  ;  $K = 0.14$  ;  $M = 1$

$I_n = 1 \text{ A}$  ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 2000 / 1$

Feeder type: Bus-Coupler

Connected to Section Nr. 1

$I_n(\text{Transformer } 63 \text{ kV side}) = 160000 / (63 \times 3^{0.5}) = 1466.29 \text{ A}$

$ISR(\text{Bus\_LV\_1}) = 0.1 \times I_n(\text{Transformer } 63 \text{ kV side}) = 146.63 \text{ A}$



$I_s = [ISR(Bus\_LV\_1) / 2000] \times I_n = 0.073 \times I_n$  ; Best Norm  $\Rightarrow 0.1 \times I_n$   
 $ISR(Bus\_LV\_1) = 0.1 \times 2000 = 200 \text{ A}$

$I_{eMax}(A3) = 1187.69 \text{ A}$

$TR(A3) = TMS(A3) / 1 \times \{0.14 / [(I_{eMax}(A3) / ISR(A3))^0.02 - 1] + 0\} = 2.525 \text{ sec}$  ;

Operating time for the Slowest Relay from lower layers

$TR(Bus\_LV\_1) = TR(A3) + 0.4 = 2.925 \text{ sec}$

$TMS = TR(Bus\_LV\_1) \times 1 / \{0.14 / [I_{eMax}(A3) / ISR(Bus\_LV\_1)]^0.02 - 1] + 0\} = 0.758$  ; High Norm  $\Rightarrow 0.775$

$I_{inst} = \text{Infinity}$

$T_{inst} = 0 \text{ sec}$ ; Norm  $\Rightarrow 0 \text{ sec}$

-----<< E/F Protection >>-----

Earth Fault Protective Relay R4(1) for 63 KV at L.V Side feeder 'Trans\_1'

Relay Type: MCGG22

Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^M + Beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$

$\alpha = 0.02$  ; Beta = 0 ; Gama = 1 ; K = 0.14 ; M = 1

$I_n = 1 \text{ A}$  ; Relay Nominal Current

C.T Ratio = I1CT / I2CT = 600 / 1

Feeder type: Trans.

Connected to Section Nr. 1

$ISR(Trans\_1) = 0.1 \times ISR(Bus\_LV\_1) = 20 \text{ A}$

$I_s = [ISR(Trans\_1) / 600] \times I_n = 0.033 \times I_n$  ; Best Norm  $\Rightarrow 0.1 \times I_n$

$ISR(Trans\_1) = 0.1 \times 600 = 60 \text{ A}$

$I_{eMax}(Bus\_LV\_1) = 1187.69 \text{ A}$

$TR(Bus\_LV\_1) = TMS(Bus\_LV\_1) / 1 \times \{0.14 / [(I_{eMax}(Bus\_LV\_1) / ISR(Bus\_LV\_1))]^{0.02 - 1] + 0\} = 2.991 \text{ sec}$  ; Operating time for the Slowest Relay from lower layers

$TR(Trans\_1) = TR(Bus\_LV\_1) + 0.4 = 3.391 \text{ sec}$

$TMS = TR(Trans\_1) \times 1 / \{0.14 / [I_{eMax}(Bus\_LV\_1) / ISR(Trans\_1)]^{0.02 - 1] + 0\} = 1.49$  ; Best Norm  $\Rightarrow 1$

$I_{inst} = \text{Infinity}$

$T_{inst} = 0 \text{ sec}$ ; Norm  $\Rightarrow 0 \text{ sec}$

-----<< E/F Protection >>-----

Earth Fault Protective Relay R4(2) for 63 KV at L.V Side feeder 'Trans\_2'

Relay Type: MCGG22

Selected Characteristic: SI



Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$   
 $\alpha = 0.02 ; \beta = 0 ; \gamma = 1 ; K = 0.14 ; M = 1$

$I_n = 1$  A ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 600 / 1$

Feeder type: Trans.

Connected to Section Nr. 2

$$ISR(Trans\_2) = 0.1 \times ISR(Bus\_LV\_1) = 20 \text{ A}$$

$$I_s = [ISR(Trans\_2) / 600] \times I_n = 0.033 \times I_n ; \text{Best Norm} ==> 0.1 \times I_n$$

$$ISR(Trans\_2) = 0.1 \times 600 = 60 \text{ A}$$

$$I_{eMax}(Bus\_LV\_1) = 1187.69 \text{ A}$$

$$TR(Bus\_LV\_1) = TMS(Bus\_LV\_1) / 1 \times \{0.14 / [(I_{eMax}(Bus\_LV\_1) / ISR(Bus\_LV\_1))^{0.02 - 1}] + 0\} = 2.991 \text{ sec} ; \text{Operating time for the Slowest Relay from lower layers}$$

$$TR(Trans\_2) = TR(Bus\_LV\_1) + 0.4 = 3.391 \text{ sec}$$

$$TMS = TR(Trans\_2) \times 1 / \{0.14 / [I_{eMax}(Bus\_LV\_1) / ISR(Trans\_2)]^{0.02 - 1} + 0\} = 1.49 ; \text{Best Norm} ==> 1$$

$I_{inst} = \text{Infinity}$

$T_{inst} = 0 \text{ sec} ; \text{Norm} ==> 0 \text{ sec}$

-----<< E/F Protection >>-----

Earth Fault Protective Relay R5(1) for 230 KV at Trans. Primary Side feeder 'HV\_1'

Relay Type: MCGG22

Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$

$\alpha = 0.02 ; \beta = 0 ; \gamma = 1 ; K = 0.14 ; M = 1$

$I_n = 1$  A ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 600 / 1$

Feeder type: Trans.

Connected to Section Nr. 1

$$I_n(\text{Transformer } 230 \text{ kV side}) = 160000 / (230 \times 3^{0.5}) = 401.63 \text{ A}$$

$$ISR(HV\_1) = 0.2 \times I_n(\text{Transformer } 230 \text{ kV side}) = 80.33 \text{ A}$$

$$I_s = [ISR(HV\_1) / 600] \times I_n = 0.134 \times I_n ; \text{Best Norm} ==> 0.15 \times I_n$$

$$ISR(HV\_1) = 0.15 \times 600 = 90 \text{ A}$$

$$I_{eMax}(Trans\_1) = 1187.69 \text{ A}$$

$$I'_{eMax}(Trans\_1) = I_{eMax}(Trans\_1) \times 0 = 0 \text{ A}$$



$I_{eMin}(Trans\_1) = 1044.73 \text{ A}$   
 $I'eMin(Trans\_1) = I_{eMin}(Trans\_1) \times 0 = 0 \text{ A}$

Checking:  $I'eMin(Trans\_1) / ISR(HV\_1) = 0$   
 $TR(Trans\_1) = TMS(Trans\_1) / 1 \times \{0.14 / [(I_{eMax}(Trans\_1) / ISR(Trans\_1)) ^ 0.02 - 1] + 0\} = 2.275 \text{ sec}$  ; Operating time for the Slowest Relay from lower layers  
 $TR(HV\_1) = TR(Trans\_1) + 0.3 = 2.575 \text{ sec}$

$TMS = TR(HV\_1) \times 1 / \{0.14 / [I'eMax(Trans\_1) / ISR(HV\_1)] ^ 0.02 - 1] + 0\} = -18.393$  ; Best Norm ==> 0.05

$Iinst = Infinity$   
 $Tinst = 0 \text{ sec}$ ; Norm ==> 0 sec

-----<< E/F Protection >>-----  
Earth Fault Protective Relay R5(2) for 230 KV at Trans. Primary Side feeder 'HV\_2'

Relay Type: MCGG22  
Selected Characteristic: SI  
Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^M + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$   
 $\alpha = 0.02$  ;  $\beta = 0$  ;  $M = 1$

$I_n = 1 \text{ A}$  ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 600 / 1$   
Feeder type: Trans.  
Connected to Section Nr. 1

$I_n(\text{Transformer } 230 \text{ kV side}) = 160000 / (230 \times 3^{0.5}) = 401.63 \text{ A}$

$ISR(HV\_2) = 0.2 \times I_n(\text{Transformer } 230 \text{ kV side}) = 80.33 \text{ A}$   
 $I_s = [ISR(HV\_2) / 600] \times I_n = 0.134 \times I_n$  ; Best Norm ==>  $0.15 \times I_n$   
 $ISR(HV\_2) = 0.15 \times 600 = 90 \text{ A}$

$I_{eMax}(Trans\_2) = 1187.69 \text{ A}$   
 $I'eMax(Trans\_2) = I_{eMax}(Trans\_2) \times 0 = 0 \text{ A}$

$I_{eMin}(Trans\_2) = 1044.73 \text{ A}$   
 $I'eMin(Trans\_2) = I_{eMin}(Trans\_2) \times 0 = 0 \text{ A}$

Checking:  $I'eMin(Trans\_2) / ISR(HV\_2) = 0$   
 $TR(Trans\_2) = TMS(Trans\_2) / 1 \times \{0.14 / [(I_{eMax}(Trans\_2) / ISR(Trans\_2)) ^ 0.02 - 1] + 0\} = 2.275 \text{ sec}$  ; Operating time for the Slowest Relay from lower layers  
 $TR(HV\_2) = TR(Trans\_2) + 0.3 = 2.575 \text{ sec}$

$TMS = TR(HV\_2) \times 1 / \{0.14 / [I'eMax(Trans\_2) / ISR(HV\_2)] ^ 0.02 - 1] + 0\} = -18.393$  ; Best Norm ==> 0.05

$Iinst = Infinity$



$I_{inst} = 0 \text{ sec}$ ; Norm  $\implies 0 \text{ sec}$

-----<< E/F Protection >>-----

Earth Fault Protective Relay R7(1) for 230 kV side Line Bay 'Abhar'

Relay Type: MCGG62

Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02$  ;  $\beta = 0$  ;  $\gamma = 1$  ;  $K = 0.14$  ;  $M = 1$

$I_n = 1 \text{ A}$  ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 1200 / 4$

Feeder type: Line

Connected to Section Nr. 1

Direction: Line side

$I_{base} = 251.02 \text{ A}$  ; Base Current

$I_{e1}(Abhar) = 24.68 \text{ pu} = 6195.22 \text{ A}$  ; Maximum 1-ph short circuit at forward Line beginning, seen by this Relay

$I_{e2}(Abhar) = 12 \text{ pu} = 3012.26 \text{ A}$  ; Maximum 1-ph short circuit at forward Line end, seen by this Relay

$I_{e5}(Abhar) = 5 \text{ pu} = 1255.11 \text{ A}$  ; Minimum 1-ph short circuit, seen by this Relay

$ISR(Abhar) = \max [I_{e5}(Abhar) / 4, 0.3 \times CT.Rating] = 360 \text{ A}$

$I_s = [ISR(Abhar) / 300] \times I_n = 1.2 \times I_n$  ; Best Norm  $\implies 1.2 \times I_n$

$ISR(Abhar) = 1.2 \times 300 = 360 \text{ A}$

Checking:  $I_{e5}(Abhar) / ISR(Abhar) = 3.49$

TMS according to required Relay Operating time for Faults in the Forward Line Beginning (Zone 1):

$TMS1 = 0.4 \times 1 / \{0.14 / [(I_{e1}(Abhar) / ISR(Abhar))^0.02 - 1] + 0\} = 0.167$

TMS according to required Relay Operating time for Faults in the Forward Line End (Zone 2):

$TMS2 = 0.8 \times 1 / \{0.14 / [(I_{e2}(Abhar) / ISR(Abhar))^0.02 - 1] + 0\} = 0.248$

$TMS(\text{Final}) = \max [\text{User defined TMS or Calculated TMS}] = 0.248$  ; High Norm  $\implies 0.25$

$I_{inst} = 0.9 \times [I_{e1} / ISR(Abhar)] \times I_s = 15.49 \times I_s$  ; Best Norm  $\implies 15 \times I_s$

$I_{inst} = 0 \text{ sec}$ ; Norm  $\implies 0 \text{ sec}$

Checking:  $[(I_{e1} - I_{e2}) / I_{e1}] \times 100 = 51.4 \%$

-----<< E/F Protection >>-----

Earth Fault Protective Relay R7(2) for 230 kV side Line Bay 'Eshragh'

Relay Type: MCGG22



Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times$

$\{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02 ; \beta = 0 ; \gamma = 1 ; K = 0.14 ; M = 1$

$I_n = 1 A$  ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 1200 / 1$

Feeder type: Reactor

Connected to Section Nr. 1

Direction: Busbar side

$I_{base} = 251.02 A$  ; Base Current

$I_{e3(Eshragh)} = 24.68 pu = 6195.22 A$  ; Maximum 1-ph short circuit at reverse Line beginning (if any)

$I_{e4(Eshragh)} = 12 pu = 3012.26 A$  ; Maximum 1-ph short circuit at reverse Line end (if any)

$I_{e5(Eshragh)} = 3.8 pu = 953.88 A$  ; Minimum 1-ph short circuit, seen by this Relay

$ISR(Eshragh) = \max [0.3 \times CT.Rating, 1.1 \times (\max I_s(\text{all of E/F Relays that are Line side or Non Directional}))] = 396 A$

$I_s = [ISR(Eshragh) / 1200] \times I_n = 0.33 \times I_n$  ; Best Norm  $\Rightarrow 0.35 \times I_n$

$ISR(Eshragh) = 0.35 \times 1200 = 420 A$

Checking:  $I_{e5(Boein Zahra)} / ISR(Eshragh) = 2.27$

Coordination with H.V side or Relays in Lower layers:

$TR(HV\_2) = 0.05 / 1 \times \{0.14 / [(I_{e3(Eshragh)} / ISR(HV\_2))^0.02 - 1] + 0\} = 0.079$  sec

$TMS5 = (TR(HV\_2) + 0.3) \times 1 / \{0.14 / [(I_{e3(Eshragh)} / ISR(Eshragh))^0.02 - 1] + 0\} = 0.15$

TMS according to required Relay Operating time for Faults in the Reverse Line beginning (Zone 1):

$TMS3 = 0.4 \times 1 / \{0.14 / [(I_{e3(Eshragh)} / ISR(Eshragh))^0.02 - 1] + 0\} = 0.158$

TMS according to required Relay Operating time for Faults in the Reverse Line End (Zone 2):

$TMS4 = 0.8 \times 1 / \{0.14 / [(I_{e4(Eshragh)} / ISR(Eshragh))^0.02 - 1] + 0\} = 0.23$

Coordination with Line E/F Relays:

$T(Abhar) = 0.25 / 1 \times \{0.14 / [(I_{e3(Eshragh)} / ISR(Abhar))^0.02 - 1] + 0\} = 0.598$  sec

$T(Eshragh) = T(Abhar) + 0.4 = 0.998$  sec

$TMS(Eshragh) = 0.998 \times 1 / \{0.14 / [(I_{e3(Eshragh)} / ISR(Eshragh))^0.02 - 1] + 0\} = 0.394$

$TMS(Final) = \max [\text{User defined TMS or Calculated TMS}] = 0.394$  ; High Norm  $\Rightarrow 0.4$



$I_{inst} = 0.9 \times [Ie3 / ISR(Eshragh)] \times Is = 13.28 \times Is$  ; Best Norm  $\implies 13 \times Is$   
 $T_{inst} = 0$  sec; Norm  $\implies 0$  sec

-----<< E/F Protection >>-----  
 Earth Fault Protective Relay R7(3) for 230 KV side Line Bay 'Boein Zahra'

Relay Type: MCGG22

Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/Is)^{\alpha} - 1]^{\gamma} Gama + Beta\} = (TMS/1) \times \{0.14 / [(I/Is)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02$  ;  $Beta = 0$  ;  $Gama = 1$  ;  $K = 0.14$  ;  $M = 1$

$I_n = 1$  A ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 1200 / 1$

Feeder type: Reactor

Connected to Section Nr. 2

Direction: Non Directional

$I_{base} = 251.02$  A ; Base Current

$Ie1(Boein Zahra) = 13.23$  pu = 3321.02 A ; Maximum 1-ph short circuit at forward Line beginning, seen by this Relay

$Ie2(Boein Zahra) = 8.04$  pu = 2018.22 A ; Maximum 1-ph short circuit at forward Line end, seen by this Relay

$Ie3(Boein Zahra) = 24.68$  pu = 6195.22 A ; Maximum 1-ph short circuit at reverse Line beginning (if any), seen by this Relay

$Ie4(Boein Zahra) = 12$  pu = 3012.26 A ; Maximum 1-ph short circuit at reverse Line end (if any), seen by this Relay

$Ie5(Boein Zahra) = 3.8$  pu = 953.88 A ; Minimum 1-ph short circuit, seen by this Relay

$ISR(Boein Zahra) = \max [Ie5(Boein Zahra) / 4, 0.3 \times CT.Rating, 1.1 \times (\max Is(\text{all of E/F Relays that are Line side or Non Directional}))] = 396$  A

$Is = [ISR(Boein Zahra) / 1200] \times I_n = 0.33 \times I_n$  ; Best Norm  $\implies 0.35 \times I_n$

$ISR(Boein Zahra) = 0.35 \times 1200 = 420$  A

Checking:  $Ie5(Boein Zahra) / ISR(Boein Zahra) = 2.27$

Coordination with H.V side or Relays in Lower layers:

$TR(HV\_2) = 0.05 / 1 \times \{0.14 / [(Ie3(Boein Zahra) / ISR(HV\_2))^0.02 - 1] + 0\} = 0.079$  sec

$TMS5 = (TR(HV\_2) + 0.3) \times 1 / \{0.14 / [(Ie3(Boein Zahra) / ISR(Boein Zahra))^0.02 - 1] + 0\} = 0.15$

Coordination with Line E/F Relays:

$T(Abhar) = 0.25 / 1 \times \{0.14 / [(Ie3(Boein Zahra) / ISR(Abhar))^0.02 - 1] + 0\} = 0.598$  sec

$T(Boein Zahra) = T(Abhar) + 0.4 = 0.998$  sec

$TMS(Boein Zahra) = 0.998 \times 1 / \{0.14 / [(Ie3(Boein Zahra) / ISR(Boein Zahra))^0.02 - 1] + 0\} = 0.15$



$$0.02 - 1] + 0\} = 0.394$$

TMS(Final) = Max [User defined TMS or Calculated TMS] = 0.449 ; High Norm ==> 0.45

$$I_{inst} = 1.3 \times [Ie1 / ISR(Boein Zahra)] \times Is = 10.28 \times Is ; \text{ Best Norm } ==> 10 \times Is$$

$T_{inst} = 0 \text{ sec}$ ; Norm ==> 0 sec

$$\text{Checking: } [(Ie1 - Ie2) / Ie1] \times 100 = 39.2 \%$$

-----<< E/F Protection >>-----

Earth Fault Protective Relay, R8(1) for 230 kV side Buscoupler feeder 'Bus\_HV'

Relay Type: MCGG82

Selected Characteristic: SI

$$\text{Generic Formula: } T = (TMS/1) \times \{K / [(I/Is)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/Is)^{0.02} - 1]^1 + 0\}$$

$$\alpha = 0.02 ; \beta = 0 ; \gamma = 1 ; K = 0.14 ; M = 1$$

$I_n = 1 \text{ A}$  ; Relay Nominal Current

$$C.T \text{ Ratio} = I1CT / I2CT = 2000 / 1$$

Feeder type: Bus-Coupler

Connected to Section Nr. 1

$I_{base} = 251.02 \text{ A}$  ; Base Current

$Ie1Max(Bus\_HV) = 32.42 \text{ Pu} = 29710.63 \text{ A}$  ; Maximum 1-ph short circuit at Line beginning, seen by this Relay

$Ie2Max(Bus\_HV) = 14 \text{ Pu} = 12830.01 \text{ A}$  ; Maximum 1-ph short circuit at smallest Line end, seen by this Relay

$Ie3Min(Bus\_HV) = 7 \text{ Pu} = 6415 \text{ A}$  ; Minimum 1-ph short circuit, seen by this Relay

$$ISR(Bus\_HV) \geq 0.2 \times I1ct(H.V) = 400 \text{ A}$$

$$ISR(Bus\_HV) \geq 360 \text{ A} ; \text{ According to Current setting of Abhar}$$

$$ISR(Bus\_HV) \geq 420 \text{ A} ; \text{ According to Current setting of Boein Zahra}$$

$$ISR = \text{Maximum all of ISRs} = 420 \text{ A}$$

$$Is = [ISR(Bus\_HV) / 2000] \times I_n = 0.21 \times I_n ; \text{ Best Norm } ==> 0.2 \times I_n$$

$$ISR(Bus\_HV) = 0.2 \times 2000 = 400 \text{ A}$$

$$\text{Checking: } Ie3min(Bus\_HV) / ISR(Bus\_HV) = 16.04$$

TMS(Final) = Max [User defined TMS or Calculated TMS] = 1 ; High Norm ==> 1

$I_{inst} = \text{Infinity}$

$T_{inst} = 0 \text{ sec}$ ; Norm ==> 0 sec

-----<< E/F Protection >>-----

Earth Fault Protective Relay R9(1) for 230 kV side Neutral Protection at feeder 'HV\_Neutral\_1'

Relay Type: MCGG22



Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times$

$\{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02 ; \beta = 0 ; \gamma = 1 ; K = 0.14 ; M = 1$

$I_n = 1 A$  ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 1200 / 1$

Feeder type: Trans.

Connected to Section Nr. 1

$I_{base} = 251.02 A$  ; Base Current

$I_{e1Max(HV\_Neutral\_1)} = 32.42 \text{ pu} = 29710.63 A$  ; Maximum 1-ph short circuit at Line beginning, seen by this Relay

$I_{e2MAX(HV\_Neutral\_1)} = 1 \text{ pu} = 916.43 A$  ; Maximum 1-ph short circuit at smallest Line end, seen by this Relay

$I_{e3Min(HV\_Neutral\_1)} = 1 \text{ pu} = 916.43 A$  ; Minimum 1-ph short circuit, seen by this Relay

$I_{L(H.V)} = 160000 / (230 \times 3^{0.5}) = 401.63 A$  ; Trans. Nominal Current at 230 kV side

$ISR(HV\_Neutral\_1) \geq 0.3 \times I_{L(H.V)} = 120.49 A$

$I_s = [ISR(HV\_Neutral\_1) / 1200] \times I_n = 0.1 \times I_n$  ; Best Norm ==>  $0.1 \times I_n$

$ISR(HV\_Neutral\_1) = 0.1 \times 1200 = 120 A$

$I_{eMax(Trans\_1)} = 1187.69 A$

$I'_{eMax(Trans\_1)} = I_{eMax(Trans\_1)} \times 0 = 0 A$

$I_{eMin(Trans\_1)} = 1044.73 A$

$I'_{eMin(Trans\_1)} = I_{eMin(Trans\_1)} \times 0 = 0 A$

Checking:  $I'_{eMin(Trans\_1)} / ISR(HV\_Neutral\_1) = 0$

$TR(Trans\_1) = TMS(Trans\_1) / 1 \times \{0.14 / [(I_{eMax(Trans\_1)} / ISR(Trans\_1))^0.02 - 1] + 0\} = 2.275 \text{ sec}$  ; Operating time for the Slowest Relay from lower layers

$TR(HV\_Neutral\_1) = TR(Trans\_1) + 0.4 = 2.675 \text{ sec}$

$TMS = TR(HV\_Neutral\_1) \times 1 / \{0.14 / [I'_{eMax(Trans\_1)} / ISR(HV\_Neutral\_1)]^0.02 - 1] + 0\} = -19.107$  ; High Norm ==> 0.05

Checking:  $I_{e3min(HV\_Neutral\_1)} / ISR(HV\_Neutral\_1) = 7.64$

Coordination with Remote substation's Relay or Fuse (You may deactivate this option):

Time of Extra Relay or Fuse = 2 sec ; Slowest Relay Operating time for  $I_{e6}$

$TR6(HV\_Neutral\_1) = 1 + 2 = 3 \text{ sec}$

$I_{e6(HV\_Neutral\_1)}$ ; Maximum common current with Extra Relay, seen by this Relay = 2 pu = 502.04 A

$TMS6 = 3 \times 1 / \{0.14 / [(I_{e6(HV\_Neutral\_1)} / ISR(HV\_Neutral\_1))^0.02 - 1] + 0\} = 0.622$



TMS(Final) = Max [User defined TMS or Calculated TMS] = 0.622 ; High Norm ==> 0.625

Iinst = Infinity

Tinst = 0 sec; Norm ==> 0 sec

-----<< E/F Protection >>-----

Earth Fault Protective Relay R9(2) for 230 kV side Neutral Protection at feeder 'HV\_Neutral\_2'

Relay Type: MCGG22

Selected Characteristic: SI

Generic Formula:  $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} Gama + Beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02$  ;  $Beta = 0$  ;  $Gama = 1$  ;  $K = 0.14$  ;  $M = 1$

$I_n = 1$  A ; Relay Nominal Current

C.T Ratio =  $I_{1CT} / I_{2CT} = 1200 / 1$

Feeder type: Trans.

Connected to Section Nr. 2

$I_{base} = 251.02$  A ; Base Current

$I_{e1Max(HV\_Neutral\_2)} = 32.42$  pu = 29710.63 A ; Maximum 1-ph short circuit at Line beginning, seen by this Relay

$I_{e2Max(HV\_Neutral\_2)} = 1$  pu = 916.43 A ; Maximum 1-ph short circuit at smallest Line end, seen by this Relay

$I_{e3Min(HV\_Neutral\_2)} = 1$  pu = 916.43 A ; Minimum 1-ph short circuit, seen by this Relay

$I_L(H.V) = 160000 / (230 \times 3^{0.5}) = 401.63$  A ; Trans. Nominal Current at 230 kV side

$ISR(HV\_Neutral\_2) \geq 0.3 \times I_L(H.V) = 120.49$  A

$I_s = [ISR(HV\_Neutral\_2) / 1200] \times I_n = 0.1 \times I_n$  ; Best Norm ==>  $0.1 \times I_n$

$ISR(HV\_Neutral\_2) = 0.1 \times 1200 = 120$  A

$I_{eMax(Trans\_2)} = 1187.69$  A

$I'_{eMax(Trans\_2)} = I_{eMax(Trans\_2)} \times 0 = 0$  A

$I_{eMin(Trans\_2)} = 1044.73$  A

$I'_{eMin(Trans\_2)} = I_{eMin(Trans\_2)} \times 0 = 0$  A

Checking:  $I'_{eMin(Trans\_2)} / ISR(HV\_Neutral\_2) = 0$

$TR(Trans\_2) = TMS(Trans\_2) / 1 \times \{0.14 / [(I_{eMax(Trans\_2)} / ISR(Trans\_2))^{0.02} - 1] + 0\} = 2.275$  sec ; Operating time for the Slowest Relay from lower layers

$TR(HV\_Neutral\_2) = TR(Trans\_2) + 0.4 = 2.675$  sec

$TMS = TR(HV\_Neutral\_2) \times 1 / \{0.14 / [I'_{eMax(Trans\_2)} / ISR(HV\_Neutral\_2)]^{0.02} - 1\} + 0\} = -19.107$  ; High Norm ==> 0.05



Checking:  $Ie3min(HV\_Neutral\_2) / ISR(HV\_Neutral\_2) = 7.64$

TMS according to required Relay Operating time for Faults in the Forward Line

Beginning (Zone 1):

$$TMS1 = 0.5 \times 1 / \{0.14 / [(Ie1(HV\_Neutral\_2) / ISR(HV\_Neutral\_2)) ^ 0.02 - 1] + 0\} = 0.416$$

TMS according to required Relay Operating time for Faults in the Forward Line End (Zone 2):

$$TMS2 = 1 \times 1 / \{0.14 / [(Ie2(HV\_Neutral\_2) / ISR(HV\_Neutral\_2)) ^ 0.02 - 1] + 0\} = 0.296$$

$TMS(Final) = \text{Max } [\text{User defined TMS or Calculated TMS}] = 0.416 ; \text{High Norm ==> } 0.425$

$Iinst = \text{Infinity}$

$Tinst = 0 \text{ sec; Norm ==> } 0 \text{ sec}$