



O/C نتایج مشروح محاسبات رله های

Company or Region Name = ZREC

Group or Checker Name = Group_1

Substation Name = Test_230kV_OK

Voltage = 230 / 63 kV

Calculation date & time = 2016 / 2 / 8 on Monday at 16:34:4

Transformer(s) Type = Autotransformer

S [Power Transformer(s) apparent power] = 160 MVA

Sbase = 100 MVA

محاسبات آزمایشی Comment for this Calculation:

..... Short circuit results :

Phase Fault Currents:

جريان خطای سه فاز دیده شده توسط رله فیدر های خروجی در حالت ماکریم سطح اتصال کوتاه شبکه و حضور ترانس های موازی:

$$IF1(\text{Substation}) = 12.56 \text{ pu} ==> 11510.35 \text{ A}$$

جريان خطای سه فاز فیدر کوپلаз در حالت ماکریم سطح اتصال کوتاه شبکه و حالت تک ترانسی بدون در نظر گرفتن اثر جریان تزریقی پست های مجاور متصل به فیدر های خروجی:

$$IF2(\text{Substation}) = 7.81 \text{ pu} ==> 7157.31 \text{ A}$$

جريان خطای سه فاز فیدر سمت اولیه در حالت ماکریم سطح اتصال کوتاه شبکه بدون در نظر گرفتن اثر جریان تزریقی پست های مجاور متصل به فیدر های خروجی:

$$IF3(\text{Substation}) = 31.86 \text{ pu} ==> 7997.56 \text{ A}$$

جريان خطای دو فاز فیدر های خروجی در حالت مینیم سطح اتصال کوتاه شبکه و حالت تک ترانسی:

$$IF4(\text{Substation}) = 4.51 \text{ pu} ==> 4133.1 \text{ A}$$

حاصل تقسیم جریان خطای دو فاز فیدر کوپلاز بر تعداد ترانس ها در حالت مینیم سطح اتصال کوتاه شبکه و حضور ترانس های موازی:

$$IF5(\text{Substation}) = 3.01 \text{ pu} ==> 2758.45 \text{ A}$$

جريان خطای دو فاز فیدر سمت اولیه در حالت مینیم سطح اتصال کوتاه شبکه:

$$IF6(\text{Substation}) = 9.07 \text{ pu} ==> 2276.77 \text{ A}$$

جریان های اتصال کوتاه فازی مورد استفاده در محاسبات:

$$IPMax(1) = 11510.35 \text{ A}$$

$$IPMax(2) = 7157.31 \text{ A}$$

$$IPMax(3) = 7157.31 \text{ A}$$

$$IPMax(4) = 7157.31 \text{ A}$$

$$IPMax(5) = 7997.56 \text{ A}$$

$$IPMin(1) = 4133.1 \text{ A}$$

$$IPMin(2) = 2758.45 \text{ A}$$



IPMin(3) = 2758.45 A
IPMin(4) = 2758.45 A
IPMin(5) = 2276.77 A

-----<< O/C Protection >>-----
Overcurrent Protective Relay R1(1) for 63 kV Outgoing feeder 'A1'

Relay Type: MCGG82
Selected Characteristic: SI
Generic Formula: $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$
 $\alpha = 0.02$; $\beta = 0$; $\gamma = 1$; $K = 0.14$; $M = 1$

$I_n = 1$ A ; Relay Nominal Current

C.T Ratio = $I_{1CT} / I_{2CT} = 800 / 1$

Feeder type: Line
Connected to Section Nr. 1

$I_{L Max} = I(\text{Load Max}) = 560$ A
 $I(\text{LTR}) = 549$ A
Direction: Line side

$I_{base} = 916.43$ A ; Base Current
 $I_{f1(A1)} = 12.58$ pu = 11528.68 A ; Maximum 3-ph short circuit at forward Line beginning, seen by this Relay
 $I_{f2(A1)} = 7.545$ pu = 6914.46 A ; Maximum 3-ph short circuit at forward Line end, seen by this Relay
 $I_{f5(A1)} = 1$ pu = 916.43 A ; Minimum 2-ph short circuit, seen by this Relay

First Choice of Relay Current Setting: $ISR(A1) = 0.5 \times I(\text{Load Max}) = 280$ A ;
According to user selection
 $\{ISR(A1) \text{ Should be } \leq \text{Min}[I_{1CT}, I(\text{LTR})]\} \implies ISR(A1) = 280$ A

$I_s = [ISR(A1) / 800] \times I_n = 0.35 \times I_n$; High Norm $\implies 0.4 \times I_n$
 $ISR(A1) = 0.4 \times 800 = 320$ A

Checking: $I_{f5(A1)} / ISR(A1) = 2.86$

$TMS(\text{Final}) = \text{Max} [\text{User defined TMS or Calculated TMS}] = 0$; Low Norm $\implies 0.05$

$I_{inst} = 0.8 \times [I_{f1(A1)} / ISR(A1)] \times I_s = 28.82 \times I_s$; Norm $\implies 29 \times I_s$
 $T_{inst} = 0$ sec; Norm $\implies 0$ sec
Checking: $[(I_{f1} - I_{f2}) / I_{f1}] \times 100 = 40$ %

Permissible Load according to Relay Current Setting:
 $I = 320$ A
 $S = 34.9$ MVA

-----<< O/C Protection >>-----



Overcurrent Protective Relay R1(2) for 63 kV Outgoing feeder 'A2'
 Comment: << fgfdggfdf. >>

Relay Type: MCGG82

Selected Characteristic: SI

Generic Formula: $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$
 $\alpha = 0.02 ; \beta = 0 ; \gamma = 1 ; K = 0.14 ; M = 1$

$I_n = 1$ A ; Relay Nominal Current

C.T Ratio = $I_{1CT} / I_{2CT} = 800 / 1$

Feeder type: Line

Connected to Section Nr. 1

$I_{L Max} = I(\text{Load Max}) = 489$ A

$I(LTR) = 489$ A

Direction: Line side

$I_{base} = 916.43$ A ; Base Current

$I_{f1(A2)} = 12.58$ pu = 11528.68 A ; Maximum 3-ph short circuit at forward Line beginning, seen by this Relay

$I_{f2(A2)} = 1.484$ pu = 1359.98 A ; Maximum 3-ph short circuit at forward Line end, seen by this Relay

$I_{f5(A2)} = 0.8$ pu = 733.14 A ; Minimum 2-ph short circuit, seen by this Relay

First Choice of Relay Current Setting: $ISR(A2) = 1 \times I(\text{Load Max}) = 489$ A ;

According to user selection

$ISR(A2) \geq I(LTR)$ Therefore: $ISR(A2) = ILTR = 489$ A

{ $ISR(A2)$ Should be $\leq \min[I_{1CT}, I(LTR)]$ } ==> $ISR(A2) = 489$ A

$I_s = [ISR(A2) / 800] \times I_n = 0.611 \times I_n$; Low Norm ==> $0.6 \times I_n$

$ISR(A2) = 0.6 \times 800 = 480$ A

Checking: $I_{f5(A2)} / ISR(A2) = 1.53$

$TMS(\text{Final}) = \max [\text{User defined TMS or Calculated TMS}] = 0.05$; High Norm ==> 0.075

$I_{inst} = 0.9 \times [I_{f1(A2)} / ISR(A2)] \times I_s = 21.62 \times I_s$; Norm ==> $22 \times I_s$

$T_{inst} = 0$ sec; Norm ==> 0 sec

Checking: $[(I_{f1} - I_{f2}) / I_{f1}] \times 100 = 88.2$ %

Permissible Load according to Relay Current Setting:

$I = 480$ A

$S = 52.4$ MVA

-----<< O/C Protection >>-----
 Overcurrent Protective Relay R1(3) for 63 kV Outgoing feeder 'A3'



Relay Type: MCGG82

Selected Characteristic: SI

Generic Formula: $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$

$\alpha = 0.02$; $\beta = 0$; $\gamma = 1$; $K = 0.14$; $M = 1$

$I_n = 1$ A ; Relay Nominal Current

C.T Ratio = $I_{1CT} / I_{2CT} = 800 / 1$

Feeder type: Reactor

Connected to Section Nr. 1

$I_{L Max} = I(\text{Load Max}) = 549$ A

$I(LTR) = 549$ A

Direction: Busbar side

$I_{base} = 916.43$ A ; Base Current

$I_{f3(A3)} = 1$ pu = 916.43 A ; Maximum 3-ph short circuit at reverse Line beginning (if any), seen by this Relay

$I_{f4(A3)} = 1$ pu = 916.43 A ; Maximum 3-ph short circuit at reverse Line end (if any), seen by this Relay

$I_{f5(A3)} = 1.397$ pu = 1280.25 A ; Minimum 2-ph short circuit, seen by this Relay

First Choice of Relay Current Setting: $ISR(A3) = 1 \times I(\text{Load Max}) = 549$ A ;

According to user selection

$ISR(A3) \geq I(LTR)$ Therefore: $ISR(A3) = ILTR = 549$ A

{ $ISR(A3)$ Should be $\leq \min[I_{1CT}, I(LTR)]$ } ==> $ISR(A3) = 549$ A

$I_s = [ISR(A3) / 800] \times I_n = 0.686 \times I_n$; Low Norm ==> $0.65 \times I_n$

$ISR(A3) = 0.65 \times 800 = 520$ A

Checking: $I_{f5(A2)} / ISR(A3) = 1.41$

TMS according to required Relay Operating time for Faults in the Reverse Line beginning (Zone 1):

$TMS3 = 0.4 \times 1 / \{0.14 / [(I_{f3(A3)} / ISR(A3))^{0.02 - 1}] + 0\} = 0.033$

TMS according to required Relay Operating time for Faults in the Reverse Line End (Zone 2):

$TMS4 = 0.8 \times 1 / \{0.14 / [(I_{f4(A3)} / ISR(A3))^{0.02 - 1}] + 0\} = 0.065$

Coordination with Line O/C Relays:

$T(A1) = 0.05 / 1 \times \{0.14 / [(I_{f3(A3)} / ISR(A1))^{0.02 - 1}] + 0\} = 0.094$ sec

$T(A3) = T(A1) + 0.4 = 0.494$ sec

$TMS(A3) = 0.494 \times 1 / \{0.14 / [(I_{f3(A3)} / ISR(A3))^{0.02 - 1}] + 0\} = 0.226$

Coordination with Line O/C Relays:

$T(A2) = 0.075 / 1 \times \{0.14 / [(I_{f3(A3)} / ISR(A2))^{0.02 - 1}] + 0\} = 0.16$ sec

$T(A3) = T(A2) + 0.4 = 0.56$ sec

$TMS(A3) = 0.56 \times 1 / \{0.14 / [(I_{f3(A3)} / ISR(A3))^{0.02 - 1}] + 0\} = 0.256$



TMS(Final) = Max [User defined TMS or Calculated TMS] = 0.256 ; Best Norm \Rightarrow
0.25

$$I_{inst} = 0.95 \times [If3(A3) / ISR(A3)] \times I_s = 1.67 \times I_s ; \text{Norm} \Rightarrow 2 \times I_s$$

$I_{inst} = 0 \text{ sec}$; Norm $\Rightarrow 0 \text{ sec}$

Permissible Load according to Relay Current Setting:

$$I = 520 \text{ A}$$

$$S = 56.7 \text{ MVA}$$

-----<< O/C Protection >>-----
Overcurrent Protective Relay R1(4) for 63 kV Outgoing feeder 'A4'

Relay Type: MCGG62

Selected Characteristic: SI

$$\text{Generic Formula: } T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$$

$$\alpha = 0.02 ; \beta = 0 ; \gamma = 1 ; K = 0.14 ; M = 1$$

$I_n = 1 \text{ A}$; Relay Nominal Current

$$C.T \text{ Ratio} = I_{1CT} / I_{2CT} = 800 / 1$$

Feeder type: Cap-Bank

Connected to Section Nr. 2

$$I_{L Max} = I(\text{Load Max}) = 549 \text{ A}$$

$$I(LTR) = 549 \text{ A}$$

Direction: NonDirectional

$I_{base} = 916.43 \text{ A}$; Base Current

$If1(A4) = 12.58 \text{ pu} = 11528.68 \text{ A}$; Maximum 3-ph short circuit at forward Line beginning, seen by this Relay

$If2(A4) = 3.84 \text{ pu} = 3519.09 \text{ A}$; Maximum 3-ph short circuit at forward Line end, seen by this Relay

$If3(A4) = 1 \text{ pu} = 916.43 \text{ A}$; Maximum 3-ph short circuit at reverse Line beginning (if any), seen by this Relay

$If4(A4) = 1 \text{ pu} = 916.43 \text{ A}$; Maximum 3-ph short circuit at reverse Line end (if any), seen by this Relay

$If5(A4) = 1.29 \text{ pu} = 1182.19 \text{ A}$; Minimum 2-ph short circuit, seen by this Relay

First Choice of Relay Current Setting: $ISR(A4) = 1.2 \times I(\text{Load Max}) = 658.8 \text{ A}$;

According to user selection

$ISR(A4) \geq I(LTR)$ Therefore: $ISR(A4) = ILTR = 549 \text{ A}$

{ $ISR(A4)$ Should be $\leq \min[I_{1CT}, I(LTR)]$ } $\Rightarrow ISR(A4) = 549 \text{ A}$

$$I_s = [ISR(A4) / 800] \times I_n = 0.686 \times I_n ; \text{Low Norm} \Rightarrow 0.65 \times I_n$$

$$ISR(A4) = 0.65 \times 800 = 520 \text{ A}$$

Checking: $If5(A2) / ISR(A4) = 1.41$



Coordination with Line O/C Relays:

$$T(A1) = 0.05 / 1 \times \{0.14 / [(If3(A4) / ISR(A1)) ^ 0.02 - 1] + 0\} = 0.329 \text{ sec}$$

$$T(A4) = T(A1) + 0.4 = 0.729 \text{ sec}$$

$$TMS (A4) = 0.729 \times 1 / \{0.14 / [(If3(A4) / ISR(A4)) ^ 0.02 - 1] + 0\} = 0.059$$

Coordination with Line O/C Relays:

$$T(A2) = 0.075 / 1 \times \{0.14 / [(If3(A4) / ISR(A2)) ^ 0.02 - 1] + 0\} = 0.807 \text{ sec}$$

$$T(A4) = T(A2) + 0.4 = 1.207 \text{ sec}$$

$$TMS (A4) = 1.207 \times 1 / \{0.14 / [(If3(A4) / ISR(A4)) ^ 0.02 - 1] + 0\} = 0.098$$

$TMS(\text{Final}) = \text{Max } [\text{User defined TMS or Calculated TMS}] = 0.098$; Best Norm ==> 0.1

$$I_{inst} = 0.7 \times [If1(A4) / ISR(A4)] \times I_s = 15.52 \times I_s ; \text{Norm} ==> 16 \times I_s$$

$T_{inst} = 0 \text{ sec}$; Norm ==> 0 sec

$$\text{Checking: } [(If1 - If2) / If1] \times 100 = 69.5 \%$$

Permissible Load according to Relay Current Setting:

$$I = 520 \text{ A}$$

$$S = 56.7 \text{ MVA}$$

-----<< O/C Protection >>-----
Overcurrent Protective Relay R2(1) for 63 KV at Buscoupler feeder 'Bus_LV_1'

Relay Type: MCGG82

Selected Characteristic: SI

$$\text{Generic Formula: } T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^M + Beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$$

$$\alpha = 0.02 ; \text{Beta} = 0 ; \text{Gama} = 1 ; K = 0.14 ; M = 1$$

$I_n = 1 \text{ A}$; Relay Nominal Current

$$C.T \text{ Ratio} = I_{1CT} / I_{2CT} = 2000 / 1$$

Feeder type: Bus-Coupler_LV

Connected to Section Nr. 1

$$I_n(\text{Transformer 63 kV side}) = 160000 / (63 \times 3^{0.5}) = 1466.29 \text{ A}$$

$$ISR(\text{Bus_LV_1}) = 1.1 \times I_n(\text{Transformer 63 kV side}) = 1612.92 \text{ A}$$

$$I_s = [ISR(\text{Bus_LV_1}) / 2000] \times I_n = 0.806 \times I_n ; \text{Best Norm} ==> 0.8 \times I_n$$

$$IPMax(A3) = 7157.31 \text{ A}$$

$$TR(A3) = TMS(A3) / 1 \times \{0.14 / [(IPMax(A3) / ISR(A3)) ^ 0.02 - 1] + 0\} = 0.65 \text{ sec} ;$$

Operating time for the Slowest Relay from lower layers

$$TR(\text{Bus_LV_1}) = TR(A3) + 0.4 = 1.05 \text{ sec}$$

$$TMS = TR(\text{Bus_LV_1}) \times 1 / \{0.14 / [(IPMax(A3) / ISR(\text{Bus_LV_1})) ^ 0.02 - 1] + 0\} = 0.228 ; \text{High Norm} ==> 0.25$$



Iinst = Infinity

Tinst = 0 sec; Norm ==> 0 sec

Permissible Load according to Relay Current Setting:

I = 1600 A

S = 174 MVA

-----<< O/C Protection >>-----

Overcurrent Protective Relay R3(1) for 63 KV at Incoming feeder 'Incoming_1'

Relay Type: MCGG62

Selected Characteristic: SI

Generic Formula: $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02$; $\beta = 0$; $\gamma = 1$; $K = 0.14$; $M = 1$

In = 1 A ; Relay Nominal Current

C.T Ratio = I1CT / I2CT = 2000 / 1

Feeder type: Trans.

Connected to Section Nr. 1

$I_n(\text{Transformer } 63 \text{ kV side}) = 160000 / (63 \times 3^{0.5}) = 1466.29 \text{ A}$

$ISR(\text{Incoming}_1) = 1.2 \times I_n(\text{Transformer } 63 \text{ kV side}) = 1759.55 \text{ A}$

$I_s = [ISR(\text{Incoming}_1) / 2000] \times I_n = 0.88 \times I_n$; Best Norm ==> $0.9 \times I_n$

$IPMax(Bus_LV_1) = 7157.31 \text{ A}$

$TR(Bus_LV_1) = TMS(Bus_LV_1) / 1 \times \{0.14 / [(IPMax(Bus_LV_1) / ISR(Bus_LV_1))^{0.02} - 1] + 0\} = 1.151 \text{ sec}$; Operating time for the Slowest Relay from lower layers

$TR(\text{Incoming}_1) = TR(Bus_LV_1) + 0.4 = 1.551 \text{ sec}$

$TMS = TR(\text{Incoming}_1) \times 1 / \{0.14 / [(IPMax(Bus_LV_1) / ISR(\text{Incoming}_1))^{0.02} - 1] + 0\} = 0.31$; High Norm ==> 0.325

Iinst = Infinity

Tinst = 0 sec; Norm ==> 0 sec

Permissible Load according to Relay Current Setting:

I = 1800 A

S = 196 MVA

-----<< O/C Protection >>-----

Overcurrent Protective Relay R3(2) for 63 KV at Incoming feeder 'Incoming_2'

Relay Type: MCGG62

Selected Characteristic: SI

Generic Formula: $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times$



$\{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$
 $\text{alfa} = 0.02 ; \text{Beta} = 0 ; \text{Gama} = 1 ; \text{K} = 0.14 ; \text{M} = 1$

$I_n = 1 \text{ A}$; Relay Nominal Current

C.T Ratio = $I_{1CT} / I_{2CT} = 2000 / 1$

Feeder type: Trans.

Connected to Section Nr. 2

$I_n(\text{Transformer } 63 \text{ kV side}) = 160000 / (63 \times 3^{0.5}) = 1466.29 \text{ A}$

$\text{ISR}(\text{Incoming}_2) = 1.2 \times I_n(\text{Transformer } 63 \text{ kV side}) = 1759.55 \text{ A}$

$I_s = [\text{ISR}(\text{Incoming}_2) / 2000] \times I_n = 0.88 \times I_n$; Best Norm $\implies 0.9 \times I_n$

$\text{IPMax}(\text{Bus_LV_1}) = 7157.31 \text{ A}$

$\text{TR}(\text{Bus_LV_1}) = \text{TMS}(\text{Bus_LV_1}) / 1 \times \{0.14 / [(\text{IPMax}(\text{Bus_LV_1}) / \text{ISR}(\text{Bus_LV_1}))^{0.02 - 1}] + 0\} = 1.151 \text{ sec}$; Operating time for the Slowest Relay from lower layers

$\text{TR}(\text{Incoming}_2) = \text{TR}(\text{Bus_LV_1}) + 0.4 = 1.551 \text{ sec}$

$\text{TMS} = \text{TR}(\text{Incoming}_2) \times 1 / \{0.14 / [(\text{IPMax}(\text{Bus_LV_1}) / \text{ISR}(\text{Incoming}_2))^{0.02 - 1}] + 0\} = 0.31$; High Norm $\implies 0.325$

$I_{inst} = \text{Infinity}$

$T_{inst} = 1 \text{ sec}$; Norm $\implies 0 \text{ sec}$

Permissible Load according to Relay Current Setting:

$I = 1800 \text{ A}$

$S = 196 \text{ MVA}$

-----<< O/C Protection >>-----
 Overcurrent Protective Relay R4(1) for 63 KV at L.V Side feeder 'Trans_1'

Relay Type: MCGG62

Selected Characteristic: SI

Generic Formula: $T = (\text{TMS}/1) \times \{K / [(I/I_s)^{\text{alfa}} - 1]^{\text{Gama}} + \text{Beta}\} = (\text{TMS}/1) \times \{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$

$\text{alfa} = 0.02 ; \text{Beta} = 0 ; \text{Gama} = 1 ; \text{K} = 0.14 ; \text{M} = 1$

$I_n = 1 \text{ A}$; Relay Nominal Current

C.T Ratio = $I_{1CT} / I_{2CT} = 2500 / 1$

Feeder type: Trans.

Connected to Section Nr. 1

$\text{ISR}(\text{Trans}_1) = 1.2 \times \text{ISR}(\text{Incoming}_1) = 2160 \text{ A}$

$I_s = [\text{ISR}(\text{Trans}_1) / 2500] \times I_n = 0.864 \times I_n$; Best Norm $\implies 0.85 \times I_n$



$$IPMax(\text{Incoming}_1) = 7157.31 \text{ A}$$

$TR(\text{Incoming}_1) = TMS(\text{Incoming}_1) / 1 \times \{0.14 / [(IPMax(\text{Incoming}_1) / ISR(\text{Incoming}_1))^{0.02 - 1}] + 0\} = 1.625 \text{ sec}$; Operating time for the Slowest Relay from lower layers

$$TR(\text{Trans}_1) = TR(\text{Incoming}_1) + 0.4 = 2.025 \text{ sec}$$

$$TMS = TR(\text{Trans}_1) \times 1 / \{0.14 / [(IPMax(\text{Incoming}_1) / ISR(\text{Trans}_1))^{0.02 - 1}] + 0\} = 0.356 \text{ ; Best Norm ==> 0.35}$$

$I_{inst} = \text{Infinity}$

$T_{inst} = 0 \text{ sec; Norm ==> 0 sec}$

Permissible Load according to Relay Current Setting:

$$I = 1800 \text{ A}$$

$$S = 196 \text{ MVA}$$

-----<< O/C Protection >>-----

Overcurrent Protective Relay R4(2) for 63 KV at L.V Side feeder 'Trans_2'

Relay Type: MCGG62

Selected Characteristic: SI

$$\text{Generic Formula: } T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02 - 1}]^1 + 0\}$$

$$\alpha = 0.02 \text{ ; } \beta = 0 \text{ ; } \gamma = 1 \text{ ; } K = 0.14 \text{ ; } M = 1$$

$I_n = 1 \text{ A ; Relay Nominal Current}$

$$C.T \text{ Ratio} = I_{1CT} / I_{2CT} = 2500 / 1$$

Feeder type: Trans.

Connected to Section Nr. 2

$$ISR(\text{Trans}_2) = 1.2 \times ISR(\text{Incoming}_2) = 2160 \text{ A}$$

$$I_s = [ISR(\text{Trans}_2) / 2500] \times I_n = 0.864 \times I_n \text{ ; Best Norm ==> } 0.85 \times I_n$$

$$IPMax(\text{Incoming}_2) = 7157.31 \text{ A}$$

$TR(\text{Incoming}_2) = TMS(\text{Incoming}_2) / 1 \times \{0.14 / [(IPMax(\text{Incoming}_2) / ISR(\text{Incoming}_2))^{0.02 - 1}] + 0\} = 1.625 \text{ sec}$; Operating time for the Slowest Relay from lower layers

$$TR(\text{Trans}_2) = TR(\text{Incoming}_2) + 0.4 = 2.025 \text{ sec}$$

$$TMS = TR(\text{Trans}_2) \times 1 / \{0.14 / [(IPMax(\text{Incoming}_2) / ISR(\text{Trans}_2))^{0.02 - 1}] + 0\} = 0.356 \text{ ; Best Norm ==> 0.35}$$

$I_{inst} = \text{Infinity}$

$T_{inst} = 0 \text{ sec; Norm ==> 0 sec}$

Permissible Load according to Relay Current Setting:

$$I = 1800 \text{ A}$$

$$S = 196 \text{ MVA}$$



-----<< O/C Protection >>-----

Overcurrent Protective Relay R5(1) for 230 KV at Trans. Primary Side feeder 'HV_1'

Relay Type: MCGG62

Selected Characteristic: SI

Generic Formula: $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^M + Beta\} = (TMS/1) \times \{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02$; $Beta = 0$; $M = 1$; $K = 0.14$; $M = 1$

$I_n = 1$ A ; Relay Nominal Current

C.T Ratio = $I_{1CT} / I_{2CT} = 600 / 1$

Feeder type: Trans.

Connected to Section Nr. 1

$I_n(\text{Transformer } 230 \text{ kV side}) = 160000 / (230 \times 3^{0.5}) = 401.63$ A

$ISR(HV_1) = 1.25 \times I_n (\text{Transformer } 230 \text{ kV side}) = 502.04$ A

$I_s = [ISR(HV_1) / 600] \times I_n = 0.837 \times I_n$; Best Norm ==> $0.85 \times I_n$
 $ISR(HV_1) = 0.85 \times 600 = 510$ A

$IPMax(Trans_1) = 7157.31$ A

$I'PMax(Trans_1) = IPMax(Trans_1) \times 0.274 = 1961.1$ A

$IPMin(Trans_1) = 2758.45$ A

$I'PMin(Trans_1) = I_pMin(Trans_1) \times 0.866 = 2388.82$ A

Checking: $I'PMin(Trans_1) / ISR(HV_1) = 4.68$

$TR(Trans_1) = TMS(Trans_1) / 1 \times \{0.14 / [(IPMax(Trans_1) / ISR(Trans_1))^{0.02} - 1] + 0\} = 1.993$ sec ; Operating time for the Slowest Relay from lower layers

$TR(HV_1) = TR(Trans_1) + 0.3 = 2.293$ sec

$TMS = TR(HV_1) \times 1 / \{0.14 / [(I'PMax(Trans_1) / ISR(HV_1))^{0.02} - 1] + 0\} = 0.447$; Best Norm ==> 0.45

$Iinst = 0.9 \times [I_n (\text{Transformer } 230 \text{ kV side}) / ISR(HV_1)] \times I_s = 0.71 \times I_s$; Norm ==> $2 \times I_s$

$Tinst = 0$ sec; Norm ==> 0 sec

Permissible Load according to Relay Current Setting:

$I = 493$ A

$S = 196$ MVA

-----<< O/C Protection >>-----

Overcurrent Protective Relay R5(2) for 230 KV at Trans. Primary Side feeder 'HV_2'

Relay Type: MCGG62



Selected Characteristic: SI

Generic Formula: $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times$

$\{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02 ; \beta = 0 ; \gamma = 1 ; K = 0.14 ; M = 1$

$I_n = 1$ A ; Relay Nominal Current

C.T Ratio = $I_{1CT} / I_{2CT} = 600 / 1$

Feeder type: Trans.

Connected to Section Nr. 1

$I_n(\text{Transformer } 230 \text{ kV side}) = 160000 / (230 \times 3^{0.5}) = 401.63$ A

$ISR(HV_2) = 1.25 \times I_n (\text{Transformer } 230 \text{ kV side}) = 502.04$ A

$I_s = [ISR(HV_2) / 600] \times I_n = 0.837 \times I_n$; Best Norm ==> $0.85 \times I_n$
 $ISR(HV_2) = 0.85 \times 600 = 510$ A

$IPMax(Trans_2) = 7157.31$ A

$I'PMax(Trans_2) = IPMax(Trans_2) \times 0.274 = 1961.1$ A

$IPMin(Trans_2) = 2758.45$ A

$I'PMin(Trans_2) = IpMin(Trans_2) \times 0.866 = 2388.82$ A

Checking: $I'PMin(Trans_2) / ISR(HV_2) = 4.68$

$TR(Trans_2) = TMS(Trans_2) / 1 \times \{0.14 / [(IPMax(Trans_2) / ISR(Trans_2))^{0.02} - 1] + 0\} = 1.993$ sec ; Operating time for the Slowest Relay from lower layers

$TR(HV_2) = TR(Trans_2) + 0.3 = 2.293$ sec

$TMS = TR(HV_2) \times 1 / \{0.14 / [(I'PMax(Trans_2) / ISR(HV_2))^{0.02} - 1] + 0\} = 0.447$; Best Norm ==> 0.45

$Iinst = 0.9 \times [I_n (\text{Transformer } 230 \text{ kV side}) / ISR(HV_2)] \times I_s = 0.71 \times I_s$; Norm ==> $2 \times I_s$

$Tinst = 0$ sec; Norm ==> 0 sec

Permissible Load according to Relay Current Setting:

$I = 493$ A

$S = 196$ MVA

-----<< O/C Protection >>-----
 Overcurrent Protective Relay R7(1) for 230 kV side Line Bay 'Abhar'

Relay Type: MCGG62

Selected Characteristic: SI

Generic Formula: $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times$

$\{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02 ; \beta = 0 ; \gamma = 1 ; K = 0.14 ; M = 1$



In = 1 A ; Relay Nominal Current

C.T Ratio = I_{1CT} / I_{2CT} = 1200 / 1

Feeder type: Line

Connected to Section Nr. 1

Line Thermal Rating = 560 A

Direction: Line side

I_{base} = 251.02 A ; Base Current

I_{f1(Abhar)} = 10.925 pu = 2742.41 A ; Maximum 3-ph short circuit at forward Line beginning, seen by this Relay

I_{f2(Abhar)} = 8.52 pu = 2138.71 A ; Maximum 3-ph short circuit at forward Line end, seen by this Relay

I_{f5(Abhar)} = 5 pu = 1255.11 A ; Minimum 2-ph short circuit, seen by this Relay

ISR(Abhar) = Min [LTR, 1.2 × CT.Rating] = 560 A

I_s = [ISR(Abhar) / 1200] × In = 0.467 × In ; Best Norm ==> 0.45 × In

ISR(Abhar) = 0.45 × 1200 = 540 A

Checking: I_{f5(Abhar)} / ISR(Abhar) = 2.32

TMS(Final) = Max [User defined TMS or Calculated TMS] = 0 ; Best Norm ==> 0.05

I_{inst} = 0.9 × [I_{f1(Abhar)} / ISR(Abhar)] × I_s = 4.57 × I_s ; Norm ==> 5 × I_s

T_{inst} = 0 sec; Norm ==> 0 sec

Checking: [(I_{f1} - I_{f2}) / I_{f1}] × 100 = 22 %

-----<< O/C Protection >>-----
Overcurrent Protective Relay R7(2) for 230 kV side Line Bay 'Eshragh'

Relay Type: MCGG62

Selected Characteristic: SI

Generic Formula: T = (TMS/1) × {K / [(I/I_s)^{alfa} - 1]^{Gama} + Beta} = (TMS/1) × {0.14 / [(I/I_s)^{0.02} - 1]¹ + 0}

alfa = 0.02 ; Beta = 0 ; Gama = 1 ; K = 0.14 ; M = 1

In = 1 A ; Relay Nominal Current

C.T Ratio = I_{1CT} / I_{2CT} = 1200 / 1

Feeder type: Reactor

Connected to Section Nr. 1

Line Thermal Rating = 560 A

Direction: Busbar side

I_{base} = 251.02 A ; Base Current

I_{f3(Eshragh)} = 7 pu = 1757.15 A ; Maximum 3-ph short circuit at reverse Line



beginning (if any), seen by this Relay

If4(Eshragh) = 6 pu = 1506.13 A ; Maximum 3-ph short circuit at reverse Line end
(if any), seen by this Relay

If5(Eshragh) = 5 pu = 1255.11 A ; Minimum 2-ph short circuit, seen by this Relay

If6(Eshragh) = 8 pu = 2008.17 A ; Maximum common 3_ph short circuit with
Remote Substation

ISR(Eshragh) = Max { 1.1 × Max[Is(all of O/C Relays that are Line side or
NonDirectional)] and Min [LTR , 1.2 × CT.Rating] } Not greater than LTR = 560 A

Is = [ISR(Eshragh) / 1200] × In = 0.467 × In ; Low Norm ==> 0.45 × In

ISR(Eshragh) = 0.45 × 1200 = 540 A

Checking: If5(Boein Zahra) / ISR(Eshragh) = 2.32

Coordination with H.V side or Relays in Lower layers:

TR(HV_2)= 0.45 / 1 × {0.14 / [(If3 (Eshragh) / ISR(HV_2)) ^ 0.02 - 1] + 0} = 2.515 sec

TMS5 =(TR(HV_2) + 0.3) × 1 / {0.14 / [(If3 (Eshragh) / ISR(Eshragh)) ^ 0.02 - 1] + 0}
= 0.48

TMS according to required Relay Operating time for Faults in the Reverse Line beginning (Zone 1):

TMS3 = 0.4 × 1 / {0.14 / [(If3(Eshragh) / ISR(Eshragh)) ^ 0.02 - 1] + 0} = 0.068

TMS according to required Relay Operating time for Faults in the Reverse Line End (Zone 2):

TMS4 = 0.8 × 1 / {0.14 / [(If4(Eshragh) / ISR(Eshragh)) ^ 0.02 - 1] + 0} = 0.118

Coordination with Remote substation's Relay or Fuse (You may deactivate this option):

Time of Extra Relay or Fuse = 0.222 sec ; Operating time for If6

TR6(Eshragh) = 0.4 + 0.222 = 0.62 sec

TMS6 = 0.62 × 1 / {0.14 / [(If6(Eshragh) / ISR(Eshragh)) ^ 0.02 - 1] + 0} = 0.118

Coordination with Line O/C Relays:

T(Abhar) = 0.05 / 1 × {0.14 / [(If3(Eshragh) / ISR(Abhar)) ^ 0.02 - 1] + 0} = 0.212 sec

T(Eshragh) = T(Abhar) + 0.4 = 0.612 sec

TMS (Eshragh) = 0.612 × 1 / {0.14 / [(If3(Eshragh) / ISR(Eshragh)) ^ 0.02 - 1] + 0} = 0.144

TMS(Final) = Max [User defined TMS or Calculated TMS] = 0.48 ; Best Norm ==> 0.475

Iinst = 0.9 × [If3(Eshragh) / ISR(Eshragh)] × Is = 2.93 × Is ; Norm ==> 3 × Is

Tinst = 0 sec; Norm ==> 0 sec

-----<< O/C Protection >>-----

Overcurrent Protective Relay R7(3) for 230 kV side Line Bay 'Boein Zahra'

Relay Type: MCGG62



Selected Characteristic: SI

Generic Formula: $T = (TMS/1) \times \{K / [(I/I_s)^{\alpha} - 1]^{\gamma} + \beta\} = (TMS/1) \times$

$\{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$

$\alpha = 0.02 ; \beta = 0 ; \gamma = 1 ; K = 0.14 ; M = 1$

$I_n = 1 A$; Relay Nominal Current

C.T Ratio = $I_{1CT} / I_{2CT} = 1200 / 1$

Feeder type: Reactor

Connected to Section Nr. 2

Line Thermal Rating = 560 A

Direction: NonDirectional

$I_{base} = 251.02 A$; Base Current

$I_{f1}(\text{Boein Zahra}) = 21.95 \text{ pu} = 5509.93 A$; Maximum 3-ph short circuit at forward Line beginning, seen by this Relay

$I_{f2}(\text{Boein Zahra}) = 8 \text{ pu} = 2008.17 A$; Maximum 3-ph short circuit at forward Line end, seen by this Relay

$I_{f3}(\text{Boein Zahra}) = 7 \text{ pu} = 1757.15 A$; Maximum 3-ph short circuit at reverse Line beginning (if any), seen by this Relay

$I_{f4}(\text{Boein Zahra}) = 6 \text{ pu} = 1506.13 A$; Maximum 3-ph short circuit at reverse Line end (if any), seen by this Relay

$I_{f5}(\text{Boein Zahra}) = 5 \text{ pu} = 1255.11 A$; Minimum 2-ph short circuit, seen by this Relay

$I_{f6}(\text{Boein Zahra}) = 8 \text{ pu} = 2008.17 A$; Maximum common 3_ph short circuit with Remote Substation, seen by this Relay

$ISR(\text{Boein Zahra}) = \text{MAX} \{ 1.1 \times \text{Max}[I_s(\text{all of O/C Relays that are Line side or NonDirectional})] \text{ and } \text{Min} [LTR, 0.9 \times CT.Rating] \}$ Not greater than LTR = 560 A

$I_s = [ISR(\text{Boein Zahra}) / 1200] \times I_n = 0.467 \times I_n$; Low Norm ==> $0.45 \times I_n$

$ISR(\text{Boein Zahra}) = 0.45 \times 1200 = 540 A$

Checking: $I_{f5}(\text{Boein Zahra}) / ISR(\text{Boein Zahra}) = 2.32$

Coordination with H.V side or Relays in Lower layers:

$TR(HV_2) = 0.45 / 1 \times \{0.14 / [(I_{f3}(\text{Boein Zahra}) / ISR(HV_2))^{\alpha} - 1] + 0\} = 2.515 \text{ sec}$

$TMS5 = (TR(HV_2) + 0.3) \times 1 / \{0.14 / [(I_{f3}(\text{Boein Zahra}) / ISR(Boein Zahra))^{\alpha} - 1] + 0\} = 0.48$

Coordination with Remote substation's Relay or Fuse (You may deactivate this option):

Time of Extra Relay or Fuse = 0.222 sec ; Operating time for If6

$TR6(\text{Boein Zahra}) = 0.4 + 0.222 = 0.62 \text{ sec}$

$TMS6 = 0.62 \times 1 / \{0.14 / [(I_{f6}(\text{Boein Zahra}) / ISR(Boein Zahra))^{\alpha} - 1] + 0\} = 0.118$

Coordination with Line O/C Relays:



$$T(\text{Abhar}) = 0.05 / 1 \times \{0.14 / [(\text{If3(Boein Zahra)} / \text{ISR(Abhar)})^0.02 - 1] + 0\} = 0.293 \text{ sec}$$

$$T(\text{Boein Zahra}) = T(\text{Abhar}) + 0.4 = 0.693 \text{ sec}$$

$$\text{TMS (Boein Zahra)} = 0.693 \times 1 / \{0.14 / [(\text{If3(Boein Zahra)} / \text{ISR(Boein Zahra)})^0.02 - 1] + 0\} = 0.118$$

$$\text{TMS(Final)} = \text{Max } [\text{User defined TMS or Calculated TMS}] = 0.48 ; \text{ Best Norm } ==> 0.475$$

$$I_{inst} = 1.3 \times [\text{If1(Boein Zahra)} / \text{ISR(Boein Zahra)}] \times I_s = 13.26 \times I_s ; \text{ Norm } ==> 13 \times I_s$$

$$T_{inst} = 0 \text{ sec} ; \text{ Norm } ==> 0 \text{ sec}$$

$$\text{Checking: } [(\text{If1} - \text{If2}) / \text{If1}] \times 100 = 63.6 \%$$

-----<< O/C Protection >>-----

Overcurrent Protective Relay R8(1) for 230 kV sideSide Buscoupler feeder 'Bus_HV'

Relay Type: MCGG82

Selected Characteristic: SI

$$\text{Generic Formula: } T = (\text{TMS}/1) \times \{K / [(I/I_s)^{\alpha} - 1]^M \Gamma + \beta\} = (\text{TMS}/1) \times \{0.14 / [(I/I_s)^{0.02} - 1]^1 + 0\}$$

$$\alpha = 0.02 ; \beta = 0 ; \Gamma = 1 ; K = 0.14 ; M = 1$$

$I_n = 1 \text{ A}$; Relay Nominal Current

C.T Ratio = $I_{1CT} / I_{2CT} = 2000 / 1$

Feeder type: Bus-Coupler_HV

Connected to Section Nr. 1

$I_{base} = 251.02 \text{ A}$; Base Current

$I_{p1Max(Bus_HV)} = 31.86 \text{ Pu} = 29197.43 \text{ A}$; Maximum 3-ph short circuit at Line beginning, seen by this Relay

$I_{p2Max(Bus_HV)} = 15 \text{ Pu} = 13746.44 \text{ A}$; Maximum 3-ph short circuit at smallest Line end, seen by this Relay

$I_{p3Min(Bus_HV)} = 2 \text{ Pu} = 1832.86 \text{ A}$; Minimum 2-ph short circuit, seen by this Relay

$\text{ISR(Bus_HV)} \geq 0.5 \times I_{1ct(H.V)} = 1000 \text{ A}$

$\text{ISR(Bus_HV)} \geq 540 \text{ A}$; For (Abhar) coordination

$\text{ISR(Bus_HV)} \geq 540 \text{ A}$; For (Boein Zahra) coordination

$\text{ISR(Bus_HV)} = \text{Maximum all of ISRs} = 1000 \text{ A}$

$$I_s = [\text{ISR(Bus_HV)} / 2000] \times I_n = 0.5 \times I_n ; \text{ Best Norm } ==> 0.5 \times I_n$$

$$\text{Checking: } I_{p3Min(Bus_HV)} / \text{ISR(Bus_HV)} = 1.83$$

$$\text{TMS(Final)} = \text{Max } [\text{User defined TMS or Calculated TMS}] = 1 ; \text{ High Norm } ==> 1$$

$I_{inst} = \text{Infinity}$

$T_{inst} = 0 \text{ sec}$; Norm ==> 0 sec